

Annual Drinking Water Quality Report

2018

Breitung Township Water Department East Kingsford Water system

We're pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the water and services we have delivered to you over the past year. Our goal is and always has been, to provide you with a safe and dependable supply of drinking water.

Where does my water come from?

Our water in East Kingsford is purchased from the City of Kingsford. City of Kingsford operates five deep wells. Our water is received at the intersection of Breitung Ave. and Woodbine St.

We began purchasing water from City of Kingsford in 1996

Source Water Assessment Program.

In 2003, the Michigan Dept. Of Environmental Quality performed a source water assessment of the City of Kingsford wells. Under the provisions of the 1996 amendments of the Safe Water Drinking Act, the State of Michigan is required to develop and implement an assessment of all public water supplies. City of Kingsford wells received a score of Moderately High.

Is my water safe?

YES , I'm pleased to report that our drinking water is safe and meets Federal and State requirements.

This report shows our water quality and what it means.

Drinking Water in General

Drinking water, including bottled water, may reasonably be expected to contain some small amounts of contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Water Drinking Water Hot Line 1-800-426-4791

General Sources of Drinking Water

The sources of drinking water, both bottled and tap, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves natural occurring minerals and, in some cases radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in water before it is treated

1. Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
2. Inorganic Contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water run off, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
3. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential use.
4. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by products of industrial processes and petroleum production, and can also, come from gas stations, urban storm water runoff, and septic systems.
5. Radioactive contaminants, which can be naturally occurring, or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations, which limit the amount of certain contaminants in water provided by the public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Do I need to take special precautions?

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other micro biological contaminants are available from the Safe Drinking Water Hot line (800-426-4791).

Terms and Abbreviation

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
Parts per trillion (ppt)

Pico curies per liter (pCi/L) - Pico curies per liter is a measure of the radioactivity in water.

Action Level (AL)- the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Test Result

Contaminants Source	MCLG	MCL	Our Water	Low	High	Date	Violation	Typical
Radiological Contaminants								
Gross Alpha (pCi/l)	0	1.13	1.01	1.24		07/15/14	No	Decay of natural and manmade deposits
Gross Beta (pCi/l)	0	50	0.1	0.0	0.64	07/06/11	No	Erosion of
Radium 226	0	5.0	0.1	0.05	0.15	07/06/11	No	natural deposits
Radium 228	0	combined	0.41	0.0	0.95	07/06/11	No	
Inorganic Contaminants								
Nitrate (ppm)	0	10	2.2	.08	2.20	07/12/18	No	Fertilizer Runoff and natural
Arsenic (ppm)	0.002	0.01	.001	n/d	0.001	07/15/14	No	Natural.
Fluoride (ppm)	0	4	.05	n/d	0.05	07/12/18	No	Natural.
Barium (ppm)	2.0	2.0	0.025	n/d	0.025	07/15/14	No	Natural
Microbiological Contaminants								
Total Coliform (Positive samples in 2018)	0	0	0			2018	No	Naturally present in the environment.
Unregulated Contaminants								
Sodium	NR	NR	6.6	2.7	13.0	07/12/18	No	natural deposits.
Lead/Copper at Consumer Tap								
	AL	MCLG	Your Water	Samples > AL #95%ile				
Lead (ppb)	15.0	0	3.9	0		06/16	No	Corrosion of household Plumbing systems.
Copper (ppb)	1300	0	851	0		06/16	No	Corrosion of household Plumbing systems

LEAD: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Breitung Township is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water. You may wish to have your water tested. For information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe water drinking hot line or at [Http://www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead)

The East Kingsford distribution system currently has 483 water services that were installed between about 1925 to the present. Those services installed to residences and small businesses between 1925 to the late 1960s contained a 24 inch long section of lead pipe that connected the water main to the galvanized iron service piping. Since the late 1960s, smaller water services have been installed using type K copper pipe and no lead pipe section. In addition, over the years many water services have been repaired or replaced and the lead sections have been removed and replaced with copper pipe. The City is in the process of taking inventory of the water services that contain these short sections of lead pipe to meet the requirements of the recently changed rules to PA 399 DRINKING WATER Act and to formulate a plan to begin replacing these services. This information regarding the number of water services containing any lead pipe will be reported in future Water Quality Reports.

Per- and Polyfluoroalkyl Substances (PFAS)

Per- and polyfluoroalkyl substances (PFAS), sometimes called PFCs, are a group of chemicals that are resistant to heat, water, and oil. PFAS have been classified by the United States Environmental Protection Agency (U.S. EPA) as an emerging contaminant on the national landscape. For decades, they have been used in many industrial applications and consumer products such as carpeting, waterproof clothing, upholstery, food paper wrappings, fire-fighting foams, and metal plating. They are still used today. PFAS have been found at low levels both in the environment and in blood samples from the general U.S. population.

These chemicals are persistent, which means they do not break down in the environment. They also bioaccumulate, meaning the amount builds up over time in the blood and organs. Although our understanding of these emerging contaminants is constantly evolving, elevated levels of PFAS have the potential to cause increased cholesterol, changes in the body's hormones and immune system, decreased fertility, and increased risk of certain cancers. Links to these health effects in humans are supported by epidemiologic studies and by laboratory studies in animal models.

Are there health advisory levels?

The U.S. EPA has not established enforceable drinking water standards, called maximum contaminant levels, for these chemicals. However, the U.S. EPA has set a lifetime health advisory (LHA) level in drinking water for two PFAS: perfluorooctanoic acid (PFOA) and perfluorooctanesulfonic acid (PFOS). The PFOA and PFOS LHA is the level, or amount, *below which no harm is expected from these chemicals*. **The LHA level is 70 parts per trillion (ppt) for PFOA and 70 ppt for PFOS. If both PFOA and PFOS are present, the LHA is 70 ppt for the combined concentration.**

The amount of PFOA and PFOS combined in the sample collected from our system ranged from **ND to 3 ppt**, which is more than **23 times lower than the LHA** for the combination of these two chemicals. There are many other PFAS compounds that currently do not have LHA levels. For information on PFOA, PFOS, and other PFAS, including possible health outcomes, you may visit these websites: <https://www.epa.gov/pfas>; <https://www.atsdr.cdc.gov/pfas/>; or <http://www.michigan.gov/pfasresponse>.

Why was City of Kingsford's source water tested for PFAS?

The Michigan Department of Environmental Quality (MDEQ) has coordinated a statewide initiative to test drinking water from all schools that use well water and community water supplies for PFAS. MDEQ is taking this precautionary step to testing these drinking water sources to determine if public health actions are needed.

Who can I call if I have questions about PFAS in my drinking water?

If any resident has additional questions regarding this issue, the State of Michigan Environmental Assistance Center can be contacted at 800-662-9278. Representatives may be reached to assist with your questions Monday through Friday, 8:00 AM to 4:30 PM. You may also contact [water supply information].

Is it safe to eat fish in these areas?

Wild fish samples are being collected from local lakes and rivers. These samples will be analyzed to determine the levels of PFAS in fish and make recommendations on how much is safe to eat. Some information is already available in the State of Michigan Eat Safe Fish guides, which are available at <http://www.michigan.gov/eatsafefish>.

May I bathe or swim in water containing PFAS?

Yes, information currently available suggests that this is not a major contributor to overall exposure.

How can PFAS affect people's health?

Some scientific studies suggest that certain PFAS may affect different systems in the body. The National Center for Environmental Health (NCEH)/Agency for Toxic Substances and Disease Registry (ATSDR) is working with various partners to better understand how exposure to PFAS might affect people's health.

If you are concerned about exposure to PFAS in your drinking water, please contact the Michigan Department of Health and Human Services Toxicology Hotline at 800-648-6942, or the Center for Disease Control and Prevention/ATSDR at <https://www.cdc.gov/cdc-info/> or 800-232-4636. Currently, scientists are still learning about the health effects of exposures to PFAS, including exposure to mixtures.

What other ways could I be exposed to PFOA, PFOS and other PFAS compounds?

PFAS are used in many consumer products. They are used in food packaging such as fast food wrappers and microwave popcorn bags; waterproof and stain resistant fabrics such as outdoor clothing, upholstery, and carpeting; nonstick coatings on cookware;

and cleaning supplies including some soaps and shampoos. People can be exposed to these chemicals in house dust, indoor and outdoor air, food, and drinking water. There is still uncertainty regarding these routes of exposure and more research is necessary.

What is being done about this issue?

State and local agencies are actively working to obtain more information about this situation as quickly as possible. Additional testing of the drinking water will be conducted to demonstrate that the PFAS levels are consistent and reliably below the existing LHA. Additional monitoring in and around our region and other affected areas will also be performed by the Michigan Department of Environmental Quality, which will help us answer more questions and determine next steps.

How can I stay updated on the situation?

The state has created a website where you can find information about PFAS contamination and efforts to address it in Michigan. The site will be updated as more information becomes available. The website address is: <http://michigan.gov/pfasresponse>

We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water **IS SAFE** at these levels. All 2018 testing meets or exceeds all Federal and State requirements

If you have any questions about this report or concerning your water utility, please contact Guy Forstrom at Breitung Township Water Dept. 779-2052 Mon.- Fri. 7:30 am to 3:30 pm

Regular meetings of the Breitung Township Water Board, are held the first Thursday of EVERY OTHER the month, at the Breitung Township Hall , 3851 Menominee st. Quinnesec, MI

A copy of this report may be obtained at the Breitung Township Hall , 3851 Menominee st. Quinnesec, MI OR On line at www.breitungtwp.org